

Rule No. 17

MEASUREMENT OF SERVICE

A Meters

Domestic, industrial, institutional, and commercial sewage wastes may be measured by any device acceptable to the utility. Measuring devices may be installed on any service line at the discretion of the utility.

B. Accuracy of Meters

All devices for measuring quantities of sewage discharged from customers' premises shall be in good mechanical condition, shall be adequate in size and design for the type of service and shall maintain an accuracy within 2 percent, plus or minus, of a factory calibrated device.

(TO BE INSERTED BY UTILITY)

SERVICE LETTER NO.

582

*ldps*

ISSUED BY

D. P. STEPHENSON

NAME

(TO BE INSERTED BY C.P.U.C.)

DATE FILED

MAY 13 2003

EFFECTIVE

JUN 12 2003

DECISION NO.

03-02-044

DIRECTOR - RATES & REVENUES

TITLE

RESOLUTION NO.