Illinois Environmental Protection Agency

1021 North Grand Avenue East • P.O. Box 19276 • Springfield • Illinois • 62794-9276 • (217) 782-3397

National Pollutant Discharge Elimination System (NPDES)
CSO Discharge Monitoring Report (DMR)

Monitoring Period: Month: June Year: 2024 No. CSO Discharges Occurred: 4

Name: Illinois American Water- Alton Wastwater Treatment Plant Permit Number: IL0027464

Address: # 19 Chessen Lane

City: Alton State: IL Zip Code: 62002

Contact Person: Christopher Dunphy Phone Number: (618)-979-6314

Rain Event Start Date	Estimated Duration (hours)	Estimated Rainfall (inches)	CSO Outfalls that Discharged		Est. Discharge Duration (hours)	Est. Discharge Volume (MG)
			Outfall Number	Outfall Description		
06/08/2024	0.5	0.04	003	Central Avenue	0.5	0.0083
06/25/2024	0.25	0.08	003	Central Avenue	0.25	0.0047
06/05/2024	0	0	004	Piasa Street	0.5	0.0288
06/25/2024	0.25	0.08	004	Piasa Street	1.5	0.2692
				shields data not captured due to battery failure		
				and has been fixed		

I certify under penalty of law that I have personally examined and am familiar with the information submitted herein and based on my inquiry of those individuals immediately responsible for obtaining the information I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment. Any person who knowingly makes a false, fictitious, or fraudulent material statement, orally or in writing, to the Illinois EPA commits a Class 4 felony. A second or subsequent offense after conviction is a Class 3 felony. (415 ILCS 5/44(h))

Christopher Dunphy
Name of Principal Executive Officer

Signature

Lead Wastewater Operator
Title

7-12-24
Date