



NOTES:

1. ALL TAP CONNECTIONS MADE ON PVC OR AC PIPE REQUIRE THRUST BLOCKING ON THE TAP SLEEVE/SADDLE PRIOR TO INSTALLING PIPE OUT OF THE TAP VALVE EVEN IF JOINT RESTRAINED PIPE AND/OR CROSS BLOCK IS INSTALLED.
2. SEE DWG. NO. 0201-0601-SD52 FOR PATENT TAP CONNECTION DETAILS.

REVISIONS

**MISSOURI AMERICAN WATER STANDARD
CIVIL
PVC/AC TAP CONNECTION
DETAIL**

MISSOURI AMERICAN WATER
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING
727 CRAIG ROAD
ST. LOUIS, MO. 63141



AMERICAN WATER

DRAWN BY KKM
PROJECT ENG'R
APPROVED

DATE 01-13-12
PROJECT IP

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

0201-0601-SD49